



# MFPA Leipzig GmbH

Testing, Inspection and Certification Authority for  
Construction Products and Construction Types

Leipzig Institute for Materials Research and Testing  
Business Division III - Structural Fire Protection  
Dipl.-Ing. Sebastian Hauswaldt

Work Group 3.2 - Fire Behaviour of Building Components and special  
Constructions

J. Peitzmeier, M.Sc  
Tel.: +49 (0) 341-6582-117  
peitzmeier@mfpa-leipzig.de

---

## Classification Report No. KB 3.2/15-313-4

14 April 2016

No. Copy 1

---

Classification of fire resistance acc. to  
DIN EN 13501-2:2010-02

Subject matter: Classification of a load - bearing, space - enclosing and thermally - insulating solid wood wall construction with partial panelling with Fermacell gypsum fibreboard, t = 12.5 mm (wall side A) - according to DIN EN 13501-2:2010-02 with a one-sided exposure to fire from wall side A in the fire-resistance class REI-M 90.

Applicant: Reinverbund GmbH  
Kiefernainweg 96  
I – 39026 Prad am Stilfersjoch (BZ)  
Südtirol - Italien

Person in charge: Julian Peitzmeier, M.Sc.

The classification report is valid for an unlimited period of time.

This document consists of 5 pages.

---

This document may only be reproduced in its unabbreviated form. All publication, even in excerpts, requires the prior written permission of MFPA Leipzig GmbH. The legal binding form is the written German form with the original signatures and original stamp of the authorized signatory / signatories. General terms and conditions of MFPA Leipzig GmbH are valid.



Accredited by DAkKS GmbH. DIN EN ISO/IEC 17025 accredited testing laboratory. DIN EN ISO/IEC 17020 accredited inspection body. DIN EN ISO/IEC 17065 accredited certification body. The accreditation only applies to the methods listed in the certificate (in this document marked with \*) which can be seen on [www.mfpa-leipzig.de](http://www.mfpa-leipzig.de)

Notified testing laboratories, inspection bodies and certification bodies recognized according to the Construction Products Law (NB 800) and the State Building Code (SAC 02).

Gesellschaft für Materialforschung und Prüfungsanstalt für das Bauwesen Leipzig mbH (MFPA Leipzig GmbH)

Head Office: Hans-Weigel-Str. 2b – 04319 Leipzig/Germany  
Managing Director: Prof. Dr.-Ing. Frank Dehn  
Comm. Register: Local Court Leipzig HRB 17719  
VAT-ID: DE 813200649  
Tel.: +49 (0) 341-6582-0  
Fax: +49 (0) 341-6582-135