## This document is only the cover sheet of the original. To receive the complete document, please use the corresponding contact form on the homepage.



## MFPA Leipzig GmbH

Testing, Inspection and Certification Authority for Construction Products and Construction Types

Leipzig Institute for Materials Research and Testing **Business Division III - Structural Fire Protection** Dipl.-Ing. Sebastian Hauswaldt

Work Group 3.2 - Fire Behaviour of Building Components and special Constructions

> J. Peitzmeier, M.Sc Tel.: +49 (0) 341-6582-117 peitzmeier@mfpa-leipzig.de

## Classification Report No. KB 3.2/15-313-6

14 April 2016 No. Copy 1

Classification of fire resistance acc. to

DIN EN 13501-2:2010-02

Classification of a load - bearing, space - enclosing and thermally - insulating Subject matter:

> solid wood wall construction with partial panelling with plastered and reinforced clay construction board (wall side A) - according to DIN EN 13501-2:2010-02 with a one-sided exposure to fire from wall side A in the fire-

resistance class REI-M 120.

Reinverbund GmbH Applicant:

Kiefernhainweg 96

I – 39026 Prad am Stilfersjoch (BZ)

Südtirol - Italien

Person in charge: Julian Peitzmeier, M.Sc.

The classification report is valid for an unlimited period of time.

This document consists of 5 pages.

This document may only be reproduced in its unabbreviated form. All publication, even in excerpts, requires the prior written permission of MFPA Leipzig GmbH. The legal binding form is the written German form with the original signatures and original stamp of the authorized signatory / signatories. General terms and conditions of MFPA Leipzig GmbH are valid.

